

Cabinets are located such that they don't impede emergency egress?					
The cabinet has appropriate signage e.g. Corrosive – Acids only etc.					
A water supply is located close by?					
The corrosive cabinet is stored away from other incompatible substances?					
Acids and Bases are not stored within the same cabinet?					
Packages are closed when not in use?					
Packages are stored to minimise spillage (e.g. double contained as necessary)?					
Corrosive cabinets have self closing, close fitting and lockable doors (capable of being opened from inside)?					
The bund in the corrosive cabinet is 150mm deep and can accept 25% of the cabinet's contents? It can accommodate the largest container?					
The cabinet location does not impede access or egress?					
The walls, floor, door and roof of the cabinet are made of corrosion resistant material?					
The location of the nearest PPE, first aid and spill kit information is clearly displayed in the storage area?					
Appropriate PPE is kept in a designated, well- signposted area close by?					
A fully stocked first aid kit is located nearby and trained first aider?					
Sufficient size spill kit is located nearby with neutralising agents and absorbing materials?					

