

Reference

**Energy Efficiency Training
and Information Project**

Commercial Buildings

**Tahbik
VIC**

this project entitled "Energy Efficiency Training and

Dr Riccardo Paolini
Soheil Roumi
Dr Konstantina Vasilakopoulou
Dr Shamilia Haddad
Dr Jie Feng
Prof Deo Prasad
Prof Mattheos Santamouris

CRICOS Provider Code 00098G

Aristotle University of Thessaloniki
(Greece), School of Mechanical
Engineering, Process Equipment Design
Laboratory.

Prof. A. M. Papadopoulos
Dr. E. Giama
Dr. G. Dermentzis
Mr. A. Manoloudis
Ms. M. Symeonidou
Mr. G. Chantzis

C, A, e, A

1.

reduce final energy consumption for space heating



2. Restaurant, Standard, and Code

- National Construction Code of Australia 2019 Volume One.
- ANSI/ASHRAE 62.1-2019 Ventilation

3. Identification

for methodology replication and findings expansion to

efficiency in such buildings.

building's construction features, including the efficiency

etc.). The efficiency of the HVAC&R system (Coefficient of Performance (COP) and Seasonal Energy Efficiency

Additionally, two types of specific conditions that have a significant impact on the energy performance must

ventilation patterns, use of artificial lighting, etc.)



4. Tahbilik

In Köppen's climate classification, Tahbilik is categorised




Figure 1. Climatic data of Tahbilik [6].




Figure 2. Southern view of Tahbilk restaurant.

The classification of Tahbilk restaurant according to

The total gross floor area is 323.0 m².

cost of buildings is to improve energy efficiency.




Figure 3. Gross floor divided area of case study building.



a solar reflectance of 0.277. Also, using the average

4.2.6. Ventilation and infiltration

The supplied fresh air flow rates and the infiltration rates

Table 7. Temperature setpoints, lighting and personal heat gain.

	Building	Value	Unit	Ref.	Section and page

Table 8. Ventilation and infiltration.

information provided by TWCM, the coefficient of performance (COP) and energy efficiency ratio (EER)



	HVAC&R system	Value	Unit	Ref.	Section and page
Fresh air					
Infiltration					

Table 9. Thermal comfort parameters.

Factor	Value	Unit	Ref.	Section and page

Table 11. Scenarios for reduced energy consumption for lighting.

Base-case scenario	
Scenario 1	The lighting power density is reduced with the use of efficient light
Scenario 2	

for the improvement of the natural and artificial

1.

2.

3.


heating loads from artificial lighting, complying

existing natural and artificial lighting conditions. Using



Level	Average Daylight Factor (%)	Uniformity	sDA (%)





is the gains by infiltration;




Figure 8. Whole building energy gain for heating and cooling load – heating season (May- September).

Figure 10. Whole building energy gain for heating and cooling load – cooling season (October-April).




Figure 12. Site energy of the retrofit scenarios.

scenarios that would lead to a specific radiative forcing

address primarily cooling energy efficiency. →

Table 16. Current and future energy demand of the case study restaurant based on CSIRO weather database.

Location	Period	Site energy						Site energy variation (%)		
		DHW	Heating	Cooling	Lighting	Appliances	Total electricity	Heating	Cooling	Total electricity
Adelaide	Present	1.4	103.5	69.8	32.2	12.7	219.6	-	-	-
	2030	1.4	83.6	83.9	32.2	12.7	213.8	-19.2	20.2	-2.6
Brisbane	Present	1.4	12.5	74.0	32.2	12.7	132.8	-	-	-
	2030	1.4	8.7	92.7	32.2	12.7	147.7	-30.4	25.3	11.2
Canberra	Present	1.4	177.3	42.4	32.2	12.7	266.0	-	-	-
	2030	1.4	153.2	53.2	32.2	12.7	252.7	-13.6	25.5	-5.0
Darwin	Present	1.4	0.3	332.0	32.2	12.7	378.6	-	-	-
	2030	1.4	0.2	370.6	32.2	12.7	417.1	-33.3	11.6	10.2
Melbourne	Present	1.4	178.5	33.0	32.2	12.7	257.8	-	-	-
	2030	1.4	149.5	43.0	32.2	12.7	238.8	-16.2	30.3	-7.4
Perth	Present	1.4	56.3	103.9	32.2	12.7	206.5	-	-	-
	2030	1.4	41.4	125.3	32.2	12.7	213.0	-26.5	20.6	3.1
Sydney	Present	1.4	59.8	37.5	32.2	12.7	143.6	-	-	-
	2030	1.4	48.0	46.9	32.2	12.7	141.2	-19.7	25.1	-1.7
Hobart	Present	1.4	217.6	8.5	32.2	12.7	272.4	-	-	-
	2030	1.4	197.8	10.5	32.2	12.7	254.6	-9.1	23.5	-6.5

Table 17. The comparison between the base case and fully retrofitted scenario.

Location	Period	Loads		Site energy					Site energy variation (%)		
		Heating	Cooling	DHW	Cooling	Lighting	Appliances	Total electricity	Heating	Cooling	Total electricity
Base case	Present	16.1	30.9	1.4	11.9	32.2	12.7	74.3	-	-	-
	2030	14.5	34.9	1.4	13.4	32.2	12.7	74.2	-9.1	12.6	-0.1
Retrof t	Present	1.6	20.2	1.4	4.0	8.8	12.7	28.6	-	-	-
	2030	1.4	22.9	1.4	4.6	8.8	12.7	28.8	-6.7	15.0	0.7

A a c e 1




Fig. A1. Distribution of Average Daylight Factor.

Appendix 2





Fig. A3. Exterior views of the restaurant.




Fig. A4. Interior views of the restaurant.